

CONTROLLED OZONE UNITS



480mm Length x 150mm Depth x 150mm Height

Controlled Ozone products reduce cooking odours .

They can be controlled either by the built-in air sensor pump or by interfacing with remote monitoring sensors the at the point of discharge and/or in the kitchen. Should either level exceed the safety guideline levels, the unit dwells for ten minutes, and restarts when the levels are back to normal.

The Ozone units have been specifically designed for use in commercial kitchens. The system injects ozone into the kitchen extraction system where it reacts with the organic particulates that cause odours. These particulates are oxidised by a chemical reaction resulting in the production of carbon dioxide and water vapour. The ozone itself is consumed during the process and is converted back to oxygen.


The Co200 Professional Range is a energy efficient odour control unit. The unit via its integrated smart control system is able to react to the air volume being drawn out of the kitchen through the duct work and thus only produce the level of ozone.

BENEFITS OF THE OZONE FILTER



- Energy efficient
- Smart controlled - the unit works and reacts to system air pressure and ozone output
- Compact, lightweight and quiet operation
- Quick, easy, low-cost installation
- Low capital and running costs — up to 50% less than traditional UVC systems
- Injection into duct work - adding negligible back pressure to the system so requiring less energy to push air through the air handling system
- The Co200 professional maintains efficiency as they remain outside of the air-stream, they also require less maintenance and require less cleaning
- Can be controlled by a remote sensor
- Compliant With DEFRA 2005 DW172 BUILDING REGS PART F, G, L.

Get In Touch

 Call: [0845 6880112](tel:08456880112)
 Email: info@adremit.co.uk

Our Address

Puravent, Adremit Limited, Unit 5a, Commercial Yard,
Settle, North Yorkshire, BD24 9RH

TECHNICAL INFORMATION

Model reference: Corona Ozone

Measuring : 480 x 150 x 150 mm.

Duct work connection: 100mm circular.

Volume flow rate in ductwork: 1.9 cm³/s
per unit, subject to cooking odours.

Air residence time inside chamber: >0.5 seconds.

Pressure drop: N/A.

Weight of unit: 6Kg approx.

Electrical requirements: 220V/1ph/50/60Hz

Optional Ozone discharge sensor control to ensure that emissions stay within guidelines.



3 Controlled Ozone is compliant with DEFRA 2005
DW172 BUILDING REGS PART F, G, L.

Packaging contains: the CO214M unit, 3 pin plug, length of
air hose, 2 adaptors with fixing self tapping screws, plus
the black sensor lock.

Integral Pressure Flow Switch installed to ensure that ozone is only produced whilst the extraction fans are operating.

INSTALLATION INSTRUCTIONS

It is recommended the units are located with an injection point located closest to the source of odours, (i.e. Canopy plenum or nearest accessible point on ductwork).

The unit must always be installed before the fan, outside of the airflow with the ozone being drawn from the unit.

The Black Sensor Lock must be fitted to bypass the PLC when remote sensors are not in use.



The provided air hose should be pushed into the hose connector on the end of the unit and using the adaptor provided. The other end should be fitted into the extraction duct.

A template sheet is provided to assist with the location of fixing points.

The unit must be inspected, serviced and commissioned twice a year by a qualified engineer.



Get In Touch



Call: [0845 6880112](tel:08456880112)



Email: info@adremit.co.uk

Our Address

Puravent, Adremit Limited, Unit 5a, Commercial Yard,
Settle, North Yorkshire, BD24 9RH